



### Assessment Results Exceedance Table

Of the 86 samples collected at Church Street Elementary School, 7 (8.1%) had lead concentrations that exceeded 15 ppb. The table below details the sample locations and the laboratory results.

Church Street Elementary School - White Plains City School District				
Date	Sample ID	Floor	Location	Lead Level (ppb)
4/6/2021	001-CAFE-KF-P-05	1	Cafeteria, Steam tray faucet left, KF 05	1540
4/6/2021	001-CAFE-KF-P-06	1	Cafeteria, Steam tray faucet right, KF 06	151
4/6/2021	002-120-CF-P-34	2	Classroom 120, CF 34	150
4/6/2021	002-123-CF-P-38	2	Classroom 123, CF 38	91.1
4/6/2021	002-GIRLS-BF-P-18	2	Girls bathroom at 125, Left, BF 18	47.2
4/6/2021	02-126-BF-P-20	2	Classroom 126, BF 20	18.1
4/6/2021	02-133-BF-P-27	2	Classroom 133, BF 27	70.6