



Assessment Results Exceedance Table

Of the 95 samples collected at George Washington Elementary School, 12 (12.6%) had lead concentrations that exceeded 15 ppb. The table below details the sample locations and the laboratory results.

George Washington Elementary School - White Plains City School District				
Date	Sample ID	Floor	Location	Lead Level (ppb)
4/8/2021	001-116-CF-P-01	1	Multipurpose room 116, CF 01	53
4/8/2021	001-101-BF-P-10	1	Classroom 101, BF 10	46.4
4/8/2021	001-PE-BF-P-13	1	PE office, BF 13	58.5
4/8/2021	001-KIT-KF-P-02	1	Kitchen, Handwash sink, KF 02	83.5
4/8/2021	001-CAFE-KF-P-06	1	Cafeteria, Server tray outlet, KF 06	72
4/8/2021	002-223-CF-P-18	2	Classroom 223, CF 18	415
4/8/2021	002-236-BF-P-34	2	Boys room 236, Right, BF 34	32.6
4/8/2021	002-240-CF-P-21	2	Classroom 240, CF 21	38
4/8/2021	002-242-CF-P-22	2	Classroom 242, CF 22	595
4/8/2021	002-248-CF-P-25	2	Classroom 248, CF 25	24.6
4/8/2021	002-315-BF-P-43	2	Girls room 315, Left, BF 43	33.8
4/8/2021	002-323-CF-P-35	2	Classroom 323, CF 35	19