



Assessment Results Exceedance Table

Of the 30 samples collected at Highland Middle School, 1 (3.3%) had lead concentration that exceeded 15 ppb. The table below details the sample location and the laboratory result.

Highland Middle School - White Plains City School District				
Date	Sample ID	Floor	Location	Lead Level (ppb)
4/9/2021	001-129-KF-P-04	1	Kitchen 129, Pot filler, KF 04	24.6