



Assessment Results Exceedance Table

Of the 67 samples collected at Ridgeway Elementary School, 4 (6.0%) had lead concentrations that exceeded 15 ppb. The table below details the sample locations and the laboratory results.

Ridgeway Elementary School - White Plains City School District				
Date	Sample ID	Floor	Location	Lead Level (ppb)
4/8/2021	01-Kitchen-KF-P-02	1	Kitchen, Pot filler, KF 2	26.1
4/8/2021	01-140-CF-P-13	1	Class 140, Sink by windows, CF 13	18.9
4/8/2021	01-106-BF-P-13	1	Class 106, BF 13	19.1
4/8/2021	01-103-CF-P-39	1	Class 103, CF 39	47.6