



Assessment Results Exceedance Table

Of the 105 samples collected at White Plains High School, 4 (3.8%) had lead concentrations that exceeded 15 ppb. The table below details the sample locations and the laboratory results.

White Plains High School - White Plains School District				
Date	Sample ID	Floor	Location	Lead Level (ppb)
4/10/2021	002-E211-BF-P-04	2	Boys Locker Room, E-211, BF 04	15.9
4/10/2021	G-E16-BF-P-09	Ground	Bathroom next to Girls Locker E-16, BF 09	378
4/10/2021	G-Girls-BF-P-10	Ground	Girls Pool Locker, BF 10	21.1
4/10/2021	G-Kit-KF-P-04	Ground	H Cafeteria Kitchen, Pot filler on column, KF 04	36.7