



Assessment Results Exceedance Table

Of the 37 samples collected at Rochambeau High School, 4 (10.8%) had lead concentrations that exceeded 15 ppb. The table below details the sample locations and the laboratory results.

Rochambeau High School - White Plains City School District				
Date	Sample ID	Floor	Location	Lead Level (ppb)
4/9/2021	02-Nurse-NS-P-03	1	Nurses office, 205C, NS 3	82.7
4/9/2021	03-Girls-BF-P-21	2	Girls bathroom by 322, BF 21 (left)	58.5
4/9/2021	03-Hall-WB-P-07	2	Hall by 322, WB 7	57.9
4/9/2021	00-B-BF-P-24	Basement	Classroom B, BF 24	49.3